



**DURHAM CATHOLIC
DISTRICT SCHOOL BOARD**
Learning and Living in Faith

T20-06 Good Shepherd CS Childcare Addition
ADDENDUM NO. 10

Issued by: Purchasing Services
Durham Catholic District School Board
652 Rossland Road West
Oshawa, Ontario L1J 8M7

This addendum will form a part of the bid documents for the above noted Bid and shall be read in conjunction herewith. This addendum will take precedence over all requirements of the original bid documents and any addenda issued previously.

Bidders shall acknowledge receipt of this addendum with their electronic bid submission on the declaration page in the bidding system

This Addendum forms part of the Tender Documents and amends the Tender Documents as described below.

1. CLARIFICATIONS TO QUESTIONS

1.1 Question: Section 95100 pages 3 & 4 2.1, 2, 3. States there are 3 LAT types. Would you please ask the architect to clarify if the ceiling panels are correct? Also, we would like to know if CertainTeed grid and tiles are an acceptable equivalent?

- .1 Refer to Specification Section 09 51 00, Subsection 2.1, Materials, Paragraph 2.1.1, Acoustic Ceiling Panels, which identifies the ceiling panels by location. Typical ceilings in the new addition have type LAT1 panels. Only the Staff Room/Kitchen has LAT2, which is a washable panel. LAT3 is only for use in the existing building, and is to match the existing ceiling tile. The Room Finish Schedule on the drawings only indicates where LAT is required; the types shall be as specified.
- .2 Equivalent ceiling tile and grid by CertainTeed will be accepted as indicated below.

2. ARCHITECTURAL SPECIFICATIONS

2.1 DIVISION 09 - FINISHES

.1 Section 09 51 00 - Acoustic Ceilings

.1 Subsection 2.1, Materials

- .1 Refer to Paragraph 2.1.1, Acoustic Ceiling Panels, and in Subparagraph 2.1.1.1, revise items 2.1.1.1.1 and 2.1.1.1.2 as follows:
 - .1 Typical Ceilings (LAT1)
 - .1 Add, "or CertainTeed Performa Sereno Fine Fissured SS-497"
 - .2 Staff Room/Kitchen Ceiling (LAT2)
 - .1 Add, "or CertainTeed VinylShield A"
- .2 Refer to Paragraph 2.1.2, Suspension, Subparagraph 2.1.2.1, and in the second sentence, insert "or CertainTeed," after "Chicago Metallic".

END OF ARCHITECTURAL ADDENDUM NO. 7