



# **DURHAM CATHOLIC DISTRICT SCHOOL BOARD**

*Learning and Living in Faith*

## **T20-06 Good Shepherd CS Childcare Addition** **ADDENDUM NO. 12**

Issued by: Purchasing Services  
Durham Catholic District School Board  
652 Rossland Road West  
Oshawa, Ontario L1J 8M7

This addendum will form a part of the bid documents for the above noted Bid and shall be read in conjunction herewith. This addendum will take precedence over all requirements of the original bid documents and any addenda issued previously.

**Bidders shall acknowledge receipt of this addendum with their electronic bid submission on the declaration page in the bidding system**

### **Question 1:**

Can you please clarify the location for detail 9 & 10 on drawing A4.4 for the GWB bulkheads above CMU partitions?

### **Answer 1:**

Detail 9 and 10 are standard details where OWSJ interferes with non-load bearing masonry walls.