



**DURHAM CATHOLIC
DISTRICT SCHOOL BOARD**
Learning and Living in Faith

T20-06 Good Shephard CS Childcare Addition
ADDENDUM NO. 5

Issued by: Purchasing Services
Durham Catholic District School Board
652 Rossland Road West
Oshawa, Ontario L1J 8M7

This addendum will form a part of the bid documents for the above noted Bid and shall be read in conjunction herewith. This addendum will take precedence over all requirements of the original bid documents and any addenda issued previously.

Bidders shall acknowledge receipt of this addendum with their electronic bid submission on the declaration page in the bidding system

MECHANICAL ADDENDUM NO. M-1

The following additions, deletions, amendments and/or items of clarification are hereby made an integral part of the Tender Documents. All revisions shall be made to the drawings and/or specifications and all costs for same shall be included in the Stipulated Price.

CHANGES TO SPECIFICATIONS

1. Section 23 00 40, Air Handling and Distribution

.1 Add Article 2.10 Louvres to read as follows:

2.10 LOUVRES

.1 Louvres and associated birdscreens shall be provided by general trades.

2. Section 25 00 00, Automatic Temperature Controls

.1 Under 3.13 Sequences of Operation to add Article 8, Radiant Panels and Perimeter Radiation (DDC):.

8. RADIANT PANELS AND PERIMETER RADIATION (DDC)

.1 Space temperature sensor modulates heating control valve on a call for heat to maintain an operator defined setpoint.

END OF MECHANICAL ADDENDUM M-1