



**DURHAM CATHOLIC  
DISTRICT SCHOOL BOARD**  
*Learning and Living in Faith*

**T20-06 Good Shepherd CS Childcare Addition**  
**ADDENDUM NO. 8**

Issued by: Purchasing Services  
Durham Catholic District School Board  
652 Rossland Road West  
Oshawa, Ontario L1J 8M7

This addendum will form a part of the bid documents for the above noted Bid and shall be read in conjunction herewith. This addendum will take precedence over all requirements of the original bid documents and any addenda issued previously.

**Bidders shall acknowledge receipt of this addendum with their electronic bid submission on the declaration page in the bidding system**

**Friday, January 29, 2021**

This Addendum forms part of the Tender Documents and amends the Tender Documents as described below.

**1. CLARIFICATIONS TO QUESTIONS**

1.1 Question: "There is mentioned that there will be an updated M&E specs PART 2, however none have been posted. Can you please let me know if this updated file will be added, so that we can review and quote you on these said divisions? Please advise regarding the specifications for Division 27 & 28."

.1 It is unclear what the expectation of a "Part 2" refers to. Ellard-Willson Engineering has included all electrical, communications, and security specifications in their Division 26 specifications; there is no Division 27 or 28 being issued. Please refer to the index at the beginning of the electrical specifications for the specification sections included.

**2. ARCHITECTURAL SPECIFICATIONS**

**2.1 DIVISION 04 - MASONRY**

**.1 Section 04 05 23 - Masonry Accessories**

.1 Refer to subsection 2.1, Materials, paragraph 2.1.5

.1 In subparagraph 2.1.5.1, Brick/Block vents, revise the size of the vents to read, "400mm x 400mm. Delete the end of the sentence, after "insect screen;", and replace with, "as indicated on mechanical drawings".

.2 Delete subparagraph 2.1.5.2 entirely. Finish is to be as noted in 2.1.5.1.

**END OF ARCHITECTURAL ADDENDUM NO. 5**