



Addendum #1

**Bid Opportunity: T21-42 – Community Hub and
Classroom Alterations at Village Union Public
School**

Closing Date: Tuesday, May 11, 2020 11:00 A.M.

The following additions, deletions and/or items of clarification shall be included as an integral part of the Proposal documents and scope of work:

Items of Clarification

- 1) "Electrical sub-trade shall wire the community hub barrier free washroom exhaust fan. Fan information can be found on drawing M001 - Fan Schedule. The exhaust fan must be tied into the barrier free washroom light fixture for off/on control. "

- 2) "Mechanical sub-trade shall cap off the community hub barrier free washroom supply air diffuser shown on drawing M103. "

End of Addendum #1