

**KAWARTHA PINE RIDGE DISTRICT SCHOOL BOARD
PUR24-069-ITT
Grafton Public School Classroom Upgrades**

ADDENDUM NO. 3

This addendum shall form an integral part of the bid documents for the above noted Bid and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements as it pertains to the particular and specific items noted below.

PART 1: ANSWERS TO QUESTIONS

Question 1: Question regarding IT relocation and responsibilities?

Answer 1: The board will take care of shutting down the equipment and removing it from the rack, and safely storing it. Once empty, the contractor can move the rack to the new location and bolt it to the floor. Doing this will of course take down internet/network connectivity for the entire school. We would need the Bell fibre (and all other network cables) re-routed from the existing location to the new location and brought to the rack before the board can reinstall and reconnect the equipment. Ideally, we'd want the contractor to move all the cables at the same time as the rack being moved.

PART 2: ADDITIONAL INFORMATION

Add: Addendum Form, Pinchin File No. 335495.024-01, prepared by Pinchin, (6 page)

END OF ADDENDUM NO. 3